



Hollister-Whitney Elevator Corporation

#1 Hollister-Whitney Parkway
Quincy, IL 62305
Phone: 217-222-0466

Fax: 217-222-0493
e-mail: info@hollisterwhitney.com
www.hollisterwhitney.com

November 2, 2015

IMPORTANT NOTICE

The Optional Brake Release supplied on the Hollister-Whitney geared machine should be placed in a position where the arms do not contact the plungers when not in use. We have found a possible hazardous condition if the arms are left in contact with the plungers during normal operation.




Figure 1

The picture above shows the correct position of the brake release (green arrow) when it is not being used. It is a simple matter to push the release into a position where the arms do make contact with the plungers when it needs to be used.